

January 23, 2009

Goodman Company Recalls Air Conditioner/Heat pump (PTAC) Units Due to Fire Hazard

Toronto, ON – The Electrical Safety Authority is notifying the public that Goodman Company has announced a voluntary recall of the following consumer product.

Name of Product: Air Conditioner/Heat pump (PTAC) Units.

Units: Number of the affected units in Ontario is 185 and 633 in Canada.

Manufacturer/Importer: Goodman Company, L.P.

Hazard: The PTAC’s power cords can overheat, posing a burn or fire hazard.

Incidents/Injuries: Goodman has received nine reports of smoke or fire associated with the PTAC’s power cords. No injuries have been reported.

Description/Models: The recall includes 5.0 kW Amana-brand, Comfort-Aire-brand and Century-brand PTAC units with model numbers PTxxx3x50xx (Amana) and EKTxxx-150x (Comfort-Aire and Century), and serial numbers 0702112056 through 0804237539. The model and serial numbers are located on the control board plate found under the PTAC unit’s front cover.

Sold by: Goodman and heating and cooling equipment dealers Canada wide.

When was distributed: February 2007 through June 2008 for between \$700 and \$1,000.

Manufactured in: USA

Remedy: Consumers should contact Goodman to receive a free replacement power cord. Commercial and institutional owners will be contacted directly and will install the power cord.

Consumer Contact: For additional information regarding Amana-brand units, call 1-800-366-0339 between 8 a.m. and 5 p.m. CT Monday through Friday; for Comfort-Aire and Century-brand units, call 1-877-442-4482 between 8 a.m. and 5 p.m. ET Monday through Friday; or for all products visit www.regcen.com/ptaccord.

Remarks: The recalled Air Conditioner/Heat Pump (PTAC) Units are certified to Canadian Standards by Intertek (cETL). For more information about Intertek product certification process please visit: www.intertek-etlsemko.com/portal/page/cust_portal/ITK_PGR/

