

Electrical Distribution Safety

DISTRIBUTION COMPANY AWARENESS:

This bulletin is an addition to DSB-08/07 and addresses LDCs requirements when installing generators for either permanent or temporary usage.

OESC¹ AND REG. 22/04 REQUIREMENT SCENARIOS:

Scenario #1:

If the LDC is connecting a generator (permanent or temporary) to LDC owned cables then Regulation 22/04 applies.

Scenario #2:

If the LDC is connecting a generator (permanent or temporary) to Customer owned cables or equipment then **OESC** applies, including the requirement to apply for an “Application for Inspection”.



ADDITIONAL INFORMATION:

If you can provide additional information on this Bulletin or any other Utility issue, please contact ESA to share your experiences. Additional information requests, and follow-up information, may be directed to ESA. Please be prepared to quote Bulletin “DSB-01/09”.

¹ OESC is the Ontario Electrical Safety Code