



VISUAL CHECK LIST FOR ELECTRICAL SAFETY INDUSTRIAL

Facility Name _____

Date: _____

Address _____

Observation	Yes	No	Date	Repaired
• Lights Working				
Location				
Location				
Location				
Location				
• Exit Signs Working				
Location				
• Exit Signs Visible				
• Exposed Wiring				
Location				
Location				
• Misuse or Damaged Extension Cords				
Location				
Location				
• Extensions Cords Replacing Permanent wiring				
Location				
Location				
• Broken Boxes				
Location				
Location				
• Box and Device Cover Missing				
Location				
Location				
Location				
• One Meter Clearance in Front of Electrical Equipment				
Location				
Location				
• Panel Openings (<i>finger or object can be inserted</i>)				
Location				
• Is the Electrical Room Unobstructed				
• Emergency Lights Working				
Location				
Location				
Location				
Location				
• Other Observations				
Location				
• Unapproved/Unsafe Electrical Products (<i>see list of acceptable marks</i>)				
Location				
Location				