

December 2005

Office of Information and Public Affairs

Washington, DC 20207

FOR IMMEDIATE RELEASE

[Originally](#) issued October 19, 2005

Revised October 25, 2005

Release #06-011

**Firm's Recall Hotline: (800) 649-4706**

CPSC Consumer Hotline: (800) 638-2772

CPSC Media Contact: (301) 504-7908

**CPSC, International Comfort Products LLC Announce Recall to Repair "Packaged Gas Electric" Heating and Cooling Units, or "Gas-Packs"****Note: Revised Description to Clarify Recalled Product**

WASHINGTON, D.C. - The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately unless otherwise instructed.

**Name of Product:** Certain "Packaged Gas Electric" heating and cooling units, or "Gas-Packs"

**Units:** About 28,700

**Manufacturer:** International Comfort Products LLC, of Lewisburg, Tenn.

**Hazard:** The unit's control board can ignite and, in certain units, can result in the ignition of flammable material adjacent to the unit.

**Incidents/Injuries:** The firm has received three reports of minor property damage. There are no reports of injuries.

**Description:** The recall involves certain limited "Gas-Packs" sold under the brand names Airquest, Arcoaire, Comfortmaker, Heil, Keeprite, Kenmore, ICP Commercial, and Tempstar. The affected units were manufactured between the 41st week of 2000 and the 26th

week of 2003, and are installed outside the home. The model and serial numbers of affected units are printed on the unit's rating plate as shown in the photo below. Model numbers appear in the following typical format:

PGC036K060A; serial numbers appear in the following typical format: L004112345. Affected models begin with PGC, PGF, PGS, GPFM, GPSM, or GPCM. Please contact the ICP phone number below with the complete model and serial number from your unit, or visit [www.icpusa.com](http://www.icpusa.com), for assistance in determining whether your unit is covered.

**Sold by:** Heating, ventilation, and air conditioning dealers and contractors nationwide between October 2000 and September 2005.

**Manufactured in:** U.S.

**Remedy:** Consumers with recalled units will receive a free replacement control board and capacitor installed.

**Consumer Contact:** For more information, contact ICP at (800) 649-4706 anytime, or visit the ICP Web site at [www.icpusa.com](http://www.icpusa.com)

