

August 8, 2008

Schneider Electric Recalls Type 1 NEMA Size 2 Enclosures Due to Cover Latching Hazard

Toronto, ON – The Electrical Safety Authority is notifying the public that Schneider Electric has announced a voluntary recall of the following product. Owners and operators should stop using recalled products immediately and contact Schneider to initiate the corrective action.

Name of Product: Square D brand Type 1 NEMA Size 2 Enclosures.

Units: 400 units in Canada.

Manufacturer: Schneider Electric

Hazard: The removable cover of the enclosure may not be adequately secured to the box due to a manufacturing nonconformance. Under certain short circuit conditions the cover may not contain the arcing event as required by the listing standards.

Incidents/Injuries: None reported.

Description/Models: This enclosure is used for a number of different commercial and industrial products. Only enclosures with date codes between 0736 and 0740 are affected. Date codes are located both on carton labels and inside the enclosure on the enclosure identification label.

Catalogue Reference	Description
8502SDG...	NEMA Size 2 Contactor in NEMA Type 1 Enclosure
8536SDG...	NEMA Size 2 Starter in NEMA Type 1 Enclosure
8903 LG...	Multi-pole Electrically Held Lighting Contactor In NEMA Type 1 Enclosure
8903LXG...	Multi-pole Mechanically Held Lighting Contactor In NEMA Type 1 Enclosure
8903SPG.....	NEMA 60A Lighting Contactor in NEMA Type 1 Enclosure
8910DPAG62...	NEMA Type 1 Enclosed two-pole 60 A DPA Contactor
8910DPAG63...	NEMA Type 1 Enclosed three-pole 60 A DPA Contactor
8910DPAG72...	NEMA Type 1 Enclosed two-pole 75 A DPA Contactor
8910DPAG73...	NEMA Type 1 Enclosed three-pole 75 A DPA Contactor
8911DPSG52...	NEMA Type 1 Enclosed two-pole 50 A DPS Starter
8911DPSG53...	NEMA Type 1 Enclosed three-pole 50 A DPS Starter
9991DPG3	NEMA Type 1 Enclosure Only for 60-75 A DPA Contactors
9991DPSG2...	NEMA Type 1 Enclosure Only for 50 A DPA Starters

9991LXG1...	NEMA Type 1 Enclosure Only for Multi-pole Lighting Contactors
9991SDG7...	NEMA Type 1 Enclosure Only for 8502SD... Type S Contactors
9991SDG8...	NEMA Type 1 Enclosure Only for 8536SD... Type S Starters

Sold by: Schneider Electric distributors across Canada.


When was distributed: From October 2007.

Manufactured in: Mexico

Remedy: Replace the product with the no charge replacement product and return the old product.

Consumer Contact: Contact the Schneider Electric PSA Recovery Administrator at 1-866-333-1490.

Remarks: The recalled products are certified to Canadian Standards by CSA or by UL depending on the specific model. For more information about the CSA or UL product certification process please visit: www.csa.ca or www.ul.com.



Typical enclosure design