

February 18th, 2009**Thomas Lighting Canada Recalls Lighting Fixtures due to Fall Hazard**

Toronto, ON – The Electrical Safety Authority is notifying the public that Thomas Lighting Canada has announced a voluntary recall of the following consumer product.

Name of Product: “DHO,DHE & NAT-DHO”
HIGH BAYS and LOW BAYS

Units: 10,164 in Ontario
20,755 in Canada total

Manufacturer/Importer: Thomas Lighting Canada

Hazard: If the hook fails the Luminaire can fall and there is a potential of serious injury.

Incidents/Injuries: No reports of injuries or damage. Seven faulty hooks have been reported.

Description/Models: Catalogue logic on these luminaires starts with DHO,DHE & NAT-DHO. Hooks are all the same and are all white in colour.

Sold by: Electrical Distributors

When was distributed: June of 2007 to January of 2009.

Manufactured in: Markham, Ontario & China.

Remedy: Consumers should contact Thomas Lighting Canada

All new product has been reworked to include a replacement hook. A label is attached to each ballast housing and the outside of the carton stating “ hook approved 11/25/08”, All new stock coming from China has a new hook

Consumer Contact: Joe Lamanna & Raymond Elkington @905-294-9570Ex 7226 for Joe & 7406 for Ray and Joe’s e-mail, jlamanna@thomascanada.com Address 189 Bullock Drive, Markham, Ontario L3P-1W4

Remarks: Products are certified to Canadian Standards by CSA. For more information about CSA product certification process please visit: www.csa.ca



DHO



DHE



NAT-DHO



DHO-Low Bay