

May 28, 2009

Schneider Electric Recalls Square D Double Throw Safety Switches; 30 A, 60 A and 100 A

Toronto, ON – The Electrical Safety Authority is notifying the public that Schneider Electric has announced a voluntary recall of the following industrial/commercial product. Users should take steps to initiate the replacement of affected devices immediately.

Name of Product: Square D Double Throw Safety Switch, 30 A, 60 A or 100 A rating

Units: Switches sold through electrical distributors across Canada from September 23, 2008 through March 31, 2009

Manufacturer: Schneider Electric

Hazard: There is the possibility for the switch handle to be placed in the OFF position when the switch is still in an ON (closed) position. This may result in the potential for personal injury or property damage.

Incidents/Injuries: No injuries or damage reported.

Description/Models: See catalogue number table below. This recall affects the listed catalogue numbers only, that have date codes from 08382 to 09095 only.

Sold by: Electrical distributors across Canada.

When was distributed: Between September 15 2008 to March 31, 2009.

Manufactured in: USA

Remedy: Switches with one of the indicated part numbers and having a date code within the indicated range will (a) be replaced with a new switch if currently held in inventory, or (b) be replaced with a new switch by a qualified electrical contractor if already installed in a building or facility.

Contact Information: Should you have any questions, please contact our Recovery Administration team at your convenience.

Schneider Electric
Product Recovery Administration
Phone: 1-866-333-1490
Fax: 1-866-587-4070.


Remarks: The recalled units are certified to Canadian Standards by either CSA or UL depending on catalogue number. For more information about CSA product certification process please visit: www.csa-international.org. For more information about UL product certification process please visit: www.ul.com



This Recall Notice is applicable ONLY to 30 Ampere, 60 Ampere and 100 Ampere Double Throw Safety Switch Catalogue Numbers listed below, with date codes from 08382 to 09095.


DT321	DT322	DTU362DS	DT223	DTU223RBEI	DTU363RB
DT321RB	DT322RB	DTU362DSVW	DT223RB	DTU323	DTU463AWK
DT361	DT362	DTU362RB	DT323	DTU323RB	DTU463DS
DT361RB	DT362RB	DTU362VW	DT323RB	DTU363	DTU663AWK
DTU321	DTU222	DTU462	DT363	DTU363AWK	
DTU361	DTU322	DTU462AWK	DT363RB	DTU363AWKVW	
DTU361RB	DTU362	DTU462DS	DTU223	DTU363DS	
DTU361VW	DTU362AWK	DTU662AWK	DTU223RB	DTU363DSVW	

For product in inventory, inspect the end of the shipping carton for the date code as follows.



**Manufacture date code:
08382 to 09095**

For installed product, TURN OFF POWER BEFORE ATTEMPTING TO INSPECT THE PRODUCT, and check for manufacture date code by opening the cover. Look at the wiring diagram on the inside of the cover for the manufacture date code as shown in the photos below.



**Manufacture date code:
08382 to 09095**