

February 24, 2010

## Stanley Convergent Security Solutions, Inc Recall Connector Kits Used with Sonitrol Access Control Modules

**Toronto, ON** – The Electrical Safety Authority is notifying the public that Stanley Convergent Security Solutions, Inc. has announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately.

**Name of Product:** Connector kits used with electronic door lock control modules.

**Units:** 248 shipped to Canada.

**Manufacturer/Importer:** EBY Electro, Inc. (a USA company)

**Hazard:** In the event of a fire or other emergency, a faulty connection between the pin connector and pin strip could prevent a door lock from receiving a control signal allowing egress from a building.

**Incidents/Injuries:** No incidents or injuries have been reported.

**Description/Models:** 40010751 8Z-40010751 Installation kit for ACCESS4-S Module, ACCESS4-S 8Z-ACCESS4S 4-Door Access Control Module (a 40010751 part is included in every kit); ACCESS4-SLUC 8Z-ACCESS4SC 4-Door Access Control Module (a 40010751 part is included in every kit); the pin connectors and pin strips are small enough to connect a

circuit board to an access control device such as a key card reader and automatic lock.

**Sold by:** Sonitrol franchise dealers and Stanley Convergent field officers.

**When was distributed:** Between August 2008 and October 23, 2009

**Manufactured in:** United States

**Remedy:** In an abundance of caution, the installers of such access control devices have been sent information and replacement connectors. End users will have any connectors replaced at no charge until all affected pin connectors and pin strips are replaced.

**Consumer Contact:** Ms. Kara Dean, Counsel & Assistant Secretary, 14670 Cumberland Rd., Noblesville, IN 46060, 317-703-1208.

**Remarks:** The recalled units are certified to Canadian Standards by Underwriters Laboratory Canada. For more information about Underwriters Laboratory Canada product certification process please visit: <http://www.ulc.ca/>

