

June 10, 2010

Eaton/Cutler-Hammer Recalls SMICRO6 Series Surgetrap™ Surge Protectors

The Electrical Safety Authority is notifying the public that Eaton has announced a voluntary recall of the following products. Owners and operators with recalled surge protectors installed should take steps to initiate replacement of the devices immediately.

Name of Product: This potential issue impacts 3 styles of SMICRO6 Series Surgetrap™ Surge Protectors sold between January 1, 2009 and May 21, 2010.

Manufacturer/Importer: Eaton Corporation

Hazard: The Surge protector may experience an internal short circuit when inserting a plug into one of the six outlets on the surge protector. In the event that this occurs, the surge protector may emit a spark and/or smoke. An internal fuse is designed to provide protection if this condition occurs.

Incidents/Injuries: No injuries or damage reported.

Models: SMICRO6C, SMICRO6T, SMICRO6TC

Sold by: Authorized Eaton Distributors

When was distributed: Between January 1, 2009 and May 21, 2010.

Manufactured in: China

Remedy: Owners and operators of the affected units should stop using them immediately. Steps should be taken to initiate replacement by contacting the supplier from whom they were purchased, and ask for replacements for the product by Catalog Number, and Quantity.

Contact Information: Eaton authorized distributors; Eaton Customer Service (800-268-3578) or the Perth Returns Centre @ PRCReturns@Eaton.com

Remarks: The affected units are certified to Canadian Standards by UL. For more information about the UL certification process please visit: www.ul.com.

