

April 26, 2011

Lennox Industries Recalls Garage and Unit Heaters Due to Fire Hazard

The Electrical Safety Authority is notifying the public that Lennox Industries Inc. ("Lennox") has announced a voluntary field repair action in Canada for the consumer products set out below. Consumers should stop using the affected unit immediately and contact Lennox to arrange for an inspection and, if necessary, field repair.

Name of Product: Garage heaters.

Units: Approximately 290 in Canada.

Manufacturer: Lennox Industries Inc., of Richardson, Texas or Advanced Distributor Products (ADP) LLC, of Grenada, Miss.

Hazard: Some heaters were manufactured without a required flame rollout switch, which is a back-up device that shuts down the heater in the event of a heater failure. This poses a fire hazard.

Incidents/Injuries: Lennox has not received reports of incidents associated with the affected products. No injuries have been reported.

Description/Models: This recall involves Lennox garage heaters with the model numbers and serial numbers listed below. The brand name "Lennox," the model number, and the serial number can be found on the nameplate located inside the control cabinet.

Model Number	Serial Number Range
TUA060SNAF1	5609H##### to 5610M#####
TUA100SNAF1	6004G##### to 6010L##### 5604G##### to 5610L#####
TUA100SNSF1	6004G##### to 6010L##### 5604G##### to 5610L#####
TUA125SNAF1	6004G##### to 6010L##### 5604G##### to 5610L#####
TUA125SNSF1	6004G##### to 6010L##### 5604G##### to 5610L#####

Sold by: The affected units were distributed to dealers and distributors from July 2004 through April 2011.

Remedy: Consumers should stop using these recalled heaters immediately. Consumers should contact Lennox to arrange for an inspection and, if necessary, repair of the garage heaters by an authorized manufacturer representative.

Consumer Contact: Lennox at 888-584-2353, between 8 a.m. and 4 p.m. ET Monday through Friday. For additional information on the voluntary field action, consumers can visit: www.lennox.com.

Remarks: The recalled units are certified to Canadian Standards by CSA. For more information about CSA product certification process please visit: www.csa-international.org.



