

August 2, 2012

Cooper Lighting Recalls Commercial Reflector Assembly with Glass Lens Due to Risk of Injury

The Electrical Safety Authority is notifying the public that Cooper Lighting has announced a voluntary recall of the following commercial product.

Maintenance personnel in facilities with these fixtures should check them immediately and follow the remedial action on this notice.

Name of Product: Portfolio 7-inch reflector assembly with glass lens

Units: Approximately 1,475 units distributed in Canada.

Manufacturer/Importer: Cooper Lighting LLC

Manufactured in: United States

Hazard: The reflector can fall out of its fixture to the ground, which could result in an injury.

Incidents/Injuries: Cooper Lighting has received 23 reports of reflectors falling. No injuries have been reported to the firm.

Description/Models: This recall involves circular, 7-inch diameter Portfolio aluminum reflector with glass lens designed to be inserted into a light fixture. This reflector is intended for use in indoor, commercial applications, such as office buildings, schools and shopping malls. There are four springs attached to the lip of the reflector.

The recall includes reflectors with the following catalogue descriptions: 7080*G, 7081*G, 7280*G, 7281*G, 7380*G, 7381*G, 7780*G, 7781*G, MSP5429*, MSP5443*, OLD-7280KLI4G and 7-inch reflectors with glass lens with the "PDR" (Product Deviation Request or

customized product designation) prefix; however, this description does not appear on the product. The recalled assembly is used in the following lighting fixtures: C7018*, C7042*, C7113*, C7118*, C7126*, C7142*, C7213*, C7218*, C7226*, C7242*HD7*, and MD7*.

Reflectors marked with a bar-coded stamp on their outside surface are not subject to this recall.

Sold by: Authorized distributors nationwide.

When distributed: From May 2008 through February 2012.

Remedy: Maintenance personnel in facilities with these fixtures should check them immediately, take down any units without a bar-coded stamp and contact Cooper Lighting for free replacement springs.

Consumer Contact: For additional information, contact Cooper Lighting at (800) 954-7228 between 8 a.m. and 5 p.m. ET, Monday through Friday, or visit the firm's Web site at <http://www.cooperlighting.com/>

Remarks: The recalled units are certified to Canadian Standards by UL. For more information about UL product certification process please visit: www.ul.com



HBdocs - 13027303v1