

December 27, 2012

## Liteline Corporation Recalls 2x 32W T8 Fluorescent Wrap Around Fixtures Due to Fire Hazard

The Electrical Safety Authority is notifying the public that Liteline Corporation has announced a voluntary recall of the following product and that owners or installers should stop using the recalled product immediately.

**Name of Product:** 2x32W T8 fluorescent wrap around surface mounted EPOWRAP luminaire sold under the ElectriPro brand.

**Units:** approx. 13,000 sold across Canada

**Manufacturer/Importer:** Liteline Corporation

**Manufactured in:** China

**Hazard:** The T8 sockets supplied with the unit could potentially pose a risk of fire.

**Incidents/Injuries:** As of Dec. 17, 2012 there have been four reports of sockets burning with minor property damage due to smoke. There have been no reports of injuries.

**Description/Models:** The affected fixtures have lampholders as shown in Photo1 (below.) Units provided with lampholders with green inserts as shown in Photo 2

(below) are not affected by this recall. The model of the luminaire is EPOWRAP.

It is a four-foot (1220mm) fluorescent luminaire with a white painted steel body and translucent wrap around acrylic lens, suitable for 2 x32W T8 fluorescent lamps. The product is sold under ElectriPro brand.

**Sold by:** These products were sold by NEDCO and Westburne (banners of Rexel Canada Electrical Inc.) to electrical professionals and business users.

**When distributed:** April, 2010 – April, 2011

**Remedy:** Installers and users who may have purchased the product can contact Rexel for a socket upgrade kit.

**Consumer Contact:** For more information, contact your local Westburne or NEDCO branch directly, or call 905-712-4004.

**Remarks:** The recalled units are certified to Canadian standards by UL. For more information about UL product certification process please visit: [www.ul.com](http://www.ul.com)



Photo 1



Photo 2

December 27, 2012



Photo 3



Photo 4