

---

January 14, 2015



Product Safety Alert

### **The Electrical Safety Authority Warns of Unapproved Generators Sold by Aurora Generators LLC**

The Electrical Safety Authority (ESA) is notifying the public about unapproved generators sold in Ontario by Aurora Generators LLC.

These products are unapproved, have not been tested for compliance with any Canadian Safety Standards and do not bear any recognized Canadian certification marks.

**Distributor:** Aurora Generators LLC  
1619 Coastal Highway  
Lewes, Delaware  
19958  
USA  
Tel. (954) 251-0199, (877) 510-6807  
[www.EmergencyPower.com](http://www.EmergencyPower.com) and [www.AuroraGenerators.com](http://www.AuroraGenerators.com)

**Manufacturer:** unknown

**Product:** AGI50P, 50 KVA emergency standby diesel generator.

**Direction:** End users should immediately stop using unapproved generators and ask a licensed electrical contractor to disconnect them from circuits.

**Recognized certification marks:** for the list of recognized marks please visit <http://www.esasafe.com/electricalproducts/marks> or contact ESA.

See pictures of the product on next page.

January 14, 2015

