

---

April 19, 2013



## Product Safety Alert

### **Goodman Company Recalls Amana Heating and Cooling Units (sold in the USA only) Due to Fire Hazard**

The Electrical Safety Authority is notifying the public that Goodman Company has announced a voluntary recall of the following consumer product in the United States. Consumers who may have purchased these units in the United States and returned to Canada with them should stop using recalled products immediately.

**Name of Product:** Amana Packaged Gas/Electric Heating and Cooling units.

**Manufacturer:** Goodman Company L.P., of Houston, Texas.

**Manufactured in:** United States

**Hazard:** The serial plates on the units have inaccurate information that could result in installers and servicers using undersized wiring, posing a fire hazard.

**Incidents/Injuries:** None reported

**Description/Models:** This recall involves Amana Packaged Gas/Electric Heating and Cooling units with model number APG154911541BA and serial numbers beginning with 1206, 1207, 1208, 1209 and 1210. The model and serial numbers are printed on the serial plate attached to the control compartment door on the front of the unit. The units are used to provide heating and cooling to homes and commercial buildings. Packaged units provide heating and cooling all in one system. The gray-colored units measure about 40 inches high by 51 inches wide by 47 inches deep.

**Sold by:** Heating and cooling equipment dealers in the United States only.

**When distributed:** June 2012 through October 2012 in the United States only.

**Remedy:** Consumers should contact Goodman for a free replacement of the serial plate label and a free inspection of the installation wiring. Goodman is directly contacting customers who purchased the recalled units.

**Consumer Contact:** Goodman at (800) 394-8084 from 8 a.m. to 5 p.m. CT, Monday through Friday, or online at [www.amana-hac.com](http://www.amana-hac.com) and click on "Product Recall" for more information.

**Remarks:** The affected units were intended for sale and distribution in the United States only. However, the recalled units are certified to Canadian Standards by Intertek Testing Services. For more information about Intertek Testing Services product certification process please visit: [www.Intertek.com](http://www.Intertek.com).

April 19, 2013

