

April 19, 2013

**Nexans Canada Inc. Recalls 14/2 NMD90 Heatex® Cable Due to Mislabeling on Spool**

The Electrical Safety Authority is notifying the public that Nexans Canada Inc. has announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately.

**Name of Product:** 14/2 NMD90 Heatex® Cable

**Units:** Maximum 102 spools

**Manufacturer/Importer:** Nexans Canada Inc.

**Manufactured in:** Canada

**Hazard:** Product is correctly manufactured and printed as 14/2 NMD90 Heatex® and is safe to use as such. However, product label on spool incorrectly describes product as 12/2 NMD90 Heatex®. Product should not be used in an installation requiring 12/2 NMD90 Heatex®. Potential exists for installing product in an improper application.

**Incidents/Injuries:** None to date.

**Description/Models:** Part #99138. Red overall jacket with red and black individual conductors. Supplied in 50 m lengths on metal spools.

**Sold by:** Rona

**When distributed:** October 2012

**Remedy:** Consumer should return the product to place of purchase for refund.

**Consumer Contact:** Nexans Canada Inc. , 140 Allstate Parkway, Markham, Ontario, L3R 0Z7, 1-800-268-9473 (1-800-263-2112 Quebec).

**Remarks:** The recalled units are certified to Canadian Standards by CSA. For more information about CSA product certification process please visit: [www.csa-international.org](http://www.csa-international.org)

